

## **EXECUTIVE SUMMARY**

HGC Engineering was retained by Union Gas Limited to undertake an Acoustic Assessment of the Payne Pool Station in Moore Township, Ontario. The study is required in support of an application for a Comprehensive Certificate of Approval (C of A) to the Ministry of Environment (MOE). The assessment considers all existing operable sound sources at the facility.

Source sound level measurements of existing sources were conducted at the facility on August 14, 2007. The measured source sound levels were used as input to a predictive acoustical model to quantify the environmental sound emissions associated with the facility. Acoustic assessment criteria were established in accordance with the sound level limits in MOE guideline NPC-232.

The measurements and analysis indicate that noise emissions from the Payne Pool Station are within the applicable limits, as set out in MOE publication NPC-232, during a predictable worst case hour of operation at the station.

**Table A2: Point of Reception Noise Impact Table**

| Source ID | Source Name   | Point of Reception |                       |
|-----------|---|--------------------|-----------------------|
|           |   | R1                 |                       |
|           |   | Dist [m]           | L <sub>EQ</sub> [dBA] |
| U1        | Turbine Combustion Exhaust                          | 658                | 31                    |
| NS-01     | Turbine Inlet Plenum                                | 659                | 3                     |
| NS-02     | Gas Aftercooler                                     | 644                | 35                    |
| NS-03     | Compressor Building Roof Vent (West)                | 658                | 20                    |
| NS-04     | Compressor Building Roof Vent (East)                | 659                | 22                    |
| NS-05     | Compressor Building North Ventilation Louvre (West) | 663                | 7                     |
| NS-06     | Compressor Building North Ventilation Louvre (East) | 665                | 6                     |
| NS-07     | Compressor Building East Ventilation Louvre         | 659                | 11                    |
| NS-08     | Compressor Building South Ventilation Louvre (West) | 650                | 15                    |
| NS-09     | Compressor Building South Ventilation Louvre (East) | 652                | 25                    |
| NS-10     | Compressor Building Open Man Door (East)            | 665                | 11                    |
| NS-11     | Compressor Building Open Man Door (West)            | 651                | 26                    |
| NS-12     | Compressor Building Open Sliding Door               | 657                | 32                    |

**Table A3: Acoustic Assessment Summary Table**

| Point of Reception | Point of Reception Description   | Sound Level at Point of Reception, L <sub>EQ</sub> [dBA] | Verified by Acoustic Audit | Performance Limit, L <sub>EQ</sub> [dBA] | Compliance with Performance Limit |
|--------------------|--|--|----------------------------|--|-----------------------------------|
| R1                 | Upper storey window of two storey home approx. 650 metres south of station | 39   | N                          | 40                                       | Y                                 |